
Flush Floor Duct Standard Size

AT A GLANCE...


- Folded metal body with aluminium trim.
- Finishes flush with floor.
- Available with lid trim to suit vinyl floor
- Suitable for all commercial & industrial applications.
- Flush floor cross and tee junction boxes available.
- Leveling plate aids duct height adjustment.
- Suits ECD® floor boxes.

- Fully accessible system suitable for commercial and light industrial applications.
- Galvanised steel duct body with aluminium edge trims.
- Removable screw fixed galvanised steel covers. Covers are pre-punched and countersunk.
- Supplied with leveling / joining brackets prefitted to duct body.
- Leveling / joining brackets provide facility to adjust duct height during installation.
- A full range of flush floor cross-over and tee junction boxes are available.
- This product has been examined in accordance with AS 3000 and A.C.M.A. requirements.

"Easy as ECD""



SECTION VIEW - FFDV SERIES WITH UP-STAND FOR VINYL TILES



STANDARD SIZE RANGE

| CAT. NO | DUCT SIZE (W X D) | RECESS SIZE |
|----------|----------------------|-------------|
| FFD11535 | 115 x 35 mm | 190 x 45 mm |
| FFD22535 | 225 x 35 mm | 300 x 45 mm |
| FFD22550 | 225 x 50 mm | 300 x 60 mm |
| FFD35065 | 350 x 65 mm | 420 x 75 mm |

'FFDV' WITH OPTIONAL VINYL LID TRIM AVAILABLE IN THE STANDARD SIZES ABOVE



Electric Cable Duct Systems P/L

Phone: 1300 123 ECD (323) Fax: 1 Email: info@ecd.net.au websi


Fax: 1300 372 825

website: www.ecd.net.au

ABN 80005544105

^{*}Other sizes available to order





INSTALLATION FFD SERIES

Installed into a preformed recess provided by the builder (see front page). Once duct is installed and levelled to floor level, the builder is required to grout the location.

SUGGESTED SPECIFICATION

- The contractor shall allow to supply and install Electric Cable Duct Systems P/L Cat No. FFD (see front page), Flush Floor Duct System, generally in accordance with the manufacturers technical publication and as identified on the plans and specifications of the project.
- The body shall be folded steel with aluminium trim with removable pre-punched and countersunk, galvanised steel covers.
- The system shall be a complete and workable system including levelling bracket, stop ends, access inspection ports, and floor outlet boxes.

PARTS LIST

| DESCRIPTION | PART NO. | PART NO. | PART NO. | PART NO. |
|---------------------------|------------|------------|------------|------------|
| Duct body – 2.4m lengths | FFD11535 | FFD22535 | FFD22550 | FFD35065 |
| Duct cover – 1.2m lengths | FFD11535C | FFD22535C | FFD22550C | FFD35065C |
| Cross-over junction box | FFD11535X | FFD22535X | FFD22550X | FFD35065X |
| Tee junction box | FFD11535T | FFD22535T | FFD22550T | FFD35065T |
| 90 degree bend junction | FFD11535B | FFD22535B | FFD22550B | FFD35065B |
| Access inspection ports | FFD11535AP | FFD22535AP | FFD22550AP | FFD35065AP |
| Stop End | FFD11535SE | FFD22535SE | FFD22550SE | FFD35065SE |
| Above Floor Box (Low) | AFB70 | AFB70 | AFB70 | AFB70 |
| Above Floor Box (High) | AFB20 | AFB20 | AFB20 | AFB20 |